(b) In a 100 kVA 1100/220 V, 50 Hz 1-\$

## Code: 100101/100201

## B.Tech 2nd Semester Special Exam., 2020

( New Course )

## BASIC ELECTRICAL ENGINEERING

Time: 3 hours

Full Marks: 70

## Instructions:

- (i) The marks are indicated in the right-hand margin.
- (ii) There are **NINE** questions in this paper.
- (iii) Attempt **FIVE** questions in all.
- (iv) Question No. 1 is compulsory.
- 1. Choose the correct alternative from any seven of the following: 2×7=14
  - (a) The full-load copper loss and iron loss of a transformer are 6400 W and 5000 W respectively. The copper loss and iron loss at half load will be respectively
    - (i) 3200 W and 5000 W
    - (ii) 3200 W and 2500 W
    - (iii) 1600 W and 2500 W
    - (iv) 1600 W and 5000 W

transformer with 2000 turns on the HV side, the open circuit test result gives 220 V, 91 A, 5 kW on LV side. The core-loss component of current is approximately

(i) 9-1 A

- (ii) 22·7 A
- (iii) 45 A
- (iv) 91 A
- (c) A 4-pole d.c. generator is running at 1500 r.p.m. at no load, the frequency of current in the armature winding is
  - (i) 150 Hz
  - (ii) 50 Hz
  - (iii) 0 Hz
  - (iv) 25 Hz
- (d) What is the load at which maximum efficiency occurs in case of a 3 kVA transformer with iron loss of 20 W and full-load copper loss of 100 W?
  - (i) 6.70 kVA
  - (ü) 1·54 kVA
  - (iii) 1.34 kVA
  - (iυ) 1 kVA

20AK/836

(Turn Over)

- (e) In two-wattmeter method of power measurement, if both the wattmeters show positive and equal readings, then it can be concluded that the load
  - (i) power factor is unity
  - (ii) power factor is zero
  - (iii) power factor is 0-5 leading
  - (iu), power factor is 0-5 lagging
- (f) Which among these is the least expensive protection for over current in low voltage system?
  - (i) Rewirable fuse
  - (ii) Isolator
  - (iii) Circuit breaker
  - (iu) Air breaker switch
- (a) A circuit breaker is
  - (i) power factor correcting device
  - (ii) a device to neutralize the effect of transients
  - (iii) a waveform correcting device
  - (iv) a current interrupting device

- (h) Which three-phase connection is used to in a transformer to introduce a phase difference of 30° between its output and corresponding input line voltage?
  - (i) Star-Delta
  - (ii)/Star-Star
  - (iii) Delta-Delta
  - (iv) Delta-Zigzag
- (i) Two transformers operating in parallel will share the load depending upon their https://www.akubihar.com
  - (i) ratings
  - (ii) leakage reactance
  - (iii) efficiency
  - (iv) per unit impedance
- (j) A d.c. shunt generator is supplying a load of 1.8 kW at 200 V. Its armature and filed resistances are  $0.4 \Omega$  and  $200 \Omega$  respectively. What is the generated e.m.f.?
  - (i) 190 V
  - (ii) 196 V
  - (iii) 204 V
  - (iv) 210 V

2. (a) Open and short circuit tests performed on a 500 kVA, 6600 V/2300 V, 50 Hz transformer yielded the following data:

No-load loss = 3 kW

Full-load short circuit loss = 4 kW

Calculate the load at which the transformer efficiency would be maximum for a given power factor. Calculate the efficiency for a p.f. of 0.85.

(b) Draw the neat and exact phasor diagram of the 1-φ transformer on load condition.

(a) A 3-φ, 4-pole 50 Hz, star-connected induction motor running on full-load develops a useful torque of 300 N-m. The rotor e.m.f. is completing 120 cycles per minute. If torque lost in friction is 50 N-m, calculate—


- (i) slip;
- (ii) net output power;
- (iii) rotor copper losses/phase;
- (iv) rotor resistance per phase if rotor current is 60 A in running condition.

(b) Explain the characteristics (i) T vs. Ia, (ii) N vs. Ia and (iii) N vs. T of DC shunt motor.

4. (a) A 250 V d.c. shunt motor has a shunt resistance of 200 Ω and an armature resistance of 0.3 Ω. For a given load, motor runs at 1500 r.p.m. drawing a current of 22 A from the supply. If a resistance of 150 Ω is added in series with the field winding, find the new armature current and the speed. Assume load torque constant and magnetization curve to be linear.

(b) Draw the speed torque characteristics of (i) DC series motor, (ii) DC shunt motor and (iii) DC differentially compound motor.

5. (a) Find the current  $I_2$  in the following circuit by applying Thevenin's theorem:



20AK/**836** 

(Turn Over)

7

7

20AK/836


(Continued)

7

8

6

(b) Determine the resistance between the terminals A and B in the circuit below:



- (a) Explain the AC circuits containing only inductance and capacitance clearly with equations.
  - (b) A three-phase balanced delta-connected load of (4+j8)  $\Omega$  is connected across a 400 V, 3- $\phi$  balanced supply. Determine the phase currents, line currents and power drawn by the load. Assume the phase sequence to be RYB.
- 7. (a) Write the comparison between electric circuits and magnetic circuits.
  - (b) What do you understand from the following terms?
    - (i) Silicon steel
    - (ii) Magnetostriction
    - (iii) Statically induced e.m.f.
    - (iv) Dynamically induced e.m.f.

8. (a) What do you understand by earthing? Explain a single-phase a.c. circuit connection with earthing.

(b) Explain the procedure to improve the power factor in a.c. circuits.

9. (a) What are the various DC motors available based on the excitation?

Draw their equivalent circuit.

(b) A single-phase transformer with a ratio of 440 V/110 V takes a no-load current of 5 A at 0.2 p.f. lagging. If the secondary supplies a current of 120 A at a p.f. of 0.8 lagging, estimate the current taken by the primary and draw the phasor diagram.

\*\*\*

20AK/836

( Turn Over )

7

б

8

20AK-570/836

Code: 100101/100201

8

6

7

7